



Certificate of Conformity

| Certificate num. | Registration date | Version | Valid until | |
|-------------------|-------------------|-------------|---------------------------|-------------|
| afp - 3572 | 26-Feb-2021 | Number 2 | Issue date 22-Mar-2023 | 30-Apr-2024 |

Page 1 of 3

Product designation

Redback, Model CF2142/CF2143, type A, indoor, flush-mount, emergency sound-system loudspeaker

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Altronic Distributors Pty Ltd
174 Roe Street, PERTH, WA, AUSTRALIA, 6000

Registrant

Altronic Distributors Pty Ltd
174 Roe Street, PERTH, WA, AUSTRALIA, 6000

Producer

Altronic Distributors Pty Ltd
174 Roe Street, PERTH, WA, AUSTRALIA, 6000

Conformance criteria and evaluation

The Redback, Model CF2142/CF2143, type A, indoor, flush-mount, emergency sound-system loudspeaker has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian Standard AS ISO 7240.24:2018, 'Fire detection and alarm systems - Part 24: Fire alarm loudspeakers'.

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

Kai Loh

Executive Officer – ActivFire Scheme



Schedule to Certificate of Conformity

| Certificate num. | Registration date | Version | Valid until | |
|-------------------|-------------------|-------------|---------------------------|-------------|
| afp - 3572 | 26-Feb-2021 | Number 2 | Issue date 22-Mar-2023 | 30-Apr-2024 |
| Page 2 of 3 | | | | |

Producer's description

The Redback, Model CF2142/CF2143, type A, indoor, flush-mount, emergency sound-system loudspeaker is designed to be flush-mounted into a suspended ceiling to provide emergency warning audible broadcasts. It is fitted with a 200 mm paper cone speaker driver, and is rated for a maximum power output of 15 W when provided with an input signal of 100 Vac. Five taps are provided on the included transformer for operating at a range of output levels.

This product includes a plastic circular front grill, approximately 265 mm in diameter, with a concentric pattern of holes, plus a slip-on rear cover which is fitted with two lock-nut cable glands for connection to an emergency sound system. It is fitted with six retaining clips.

This is a type A loudspeaker intended for indoor applications only.

Technical specification

The following details are a representative extract of the technical specification for the Redback, Model CF2142/CF2143, type A, indoor, flush-mount, emergency sound-system loudspeaker and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Schedule of variant designations

The following is a schedule of validated variant designations of the certified/listed equipment.

| Variant | | Description | Colour |
|---------|--------|---|-------------------------|
| Type | Ident. | | |
| Model | CF2142 | Type A, indoor, flush-mount, emergency sound-system | White housing and grill |
| | CF2143 | loudspeaker | Black housing and grill |

Schedule of properties/characteristics

The following schedule is an extract of physical and operational properties/characteristics of the certified/listed equipment.

| | |
|------------------------------|--|
| Rated noise power | 15 Watts (100V line) |
| Power taps & impedance | (100V line) 1.25W (8k Ω), 2.5W (4k Ω), 5W (2k Ω), 10W (1k Ω), 15W (668k Ω) |
| Sensitivity | 95dB (1W @ 1m), 83dB (1W @ 4m) |
| Maximum Sound Pressure Level | 104 dB (5W @ 1 m), 92dB (5W @ 4m) |
| Frequency response | 100Hz – 15kHz, 500-4kHz: \pm 5dB |
| Coverage angle (-6dB) | 500Hz: >180°, 1000Hz: 165°, 2000Hz: 85°, 4000Hz 55° |
| Environmental | Type A (for indoor applications as per standard) |
| Speaker component | 200mm (8") paper cone speaker |
| Mounting hole | 246mm \varnothing |
| Mounting method | 6 x plastic spring loaded clip |
| Line monitoring | Yes, 22 μ F bipolar capacitor |
| Applicable cable | 2.5mm ² (14 AWG) max conductor area |
| Connection | 4 way screw terminal |
| Finish | White flame retardant ABS grille (Taitalac 8540T) Clear Flame retardant ABS spring clips (Makrolon 6557) Red flame retardant ABS transformer dome cover (Starex VH-0800) |
| Dimensions | 266 \varnothing x 103Dmm |
| Weight | 1.95kg |

Schedule to Certificate of Conformity

| Certificate num. | Registration date | Version | Valid until | |
|-------------------|-------------------|-------------|---------------------------|-------------|
| afp - 3572 | 26-Feb-2021 | Number 2 | Issue date 22-Mar-2023 | 30-Apr-2024 |
| Page 3 of 3 | | | | |

Supplementary information

Schedule of relevant articles

The following schedule is an extract of articles significant and/or related as evidence of conformity.

| Reference | | Title / description | Date issued (or date validated) | Source |
|-------------|-----------|---|------------------------------------|---------------------------------------|
| Ident. type | Ident. | | | |
| Report | XF3338/R2 | Evaluation for Conformity of the Redback, Model CF2142/CF2143, type A, indoor, flush-mount, emergency sound-system loudspeaker to the requirements of AS ISO 7240.24:2015 | 23-Dec-2020 | CSIRO, Fire Systems Laboratory, AU |
| Data Sheet | CF2142 | Redback Data Sheet CF2142 200mm (8") 100V 15W Ceiling Speaker White AS ISO7240.24 CF2143 200mm (8") 100V 15W Ceiling Speaker Black AS ISO7240.24 (CF2142 Datasheet 01-05-20.pdf) | 24-Apr-2020 | Altronic Distributors Pty Ltd, WA, AU |