

CSIRO Verification Services Clayton, Victoria, Australia +61 13 0036 3400 https://activfire.csiro.au

Certificate of Conformity

 Certificate num.
 Registration date
 Version
 Valid until

 afp - 3702
 27-Oct-2022
 Number 1 ssue date 27-Oct-2022
 30-Apr-2024

Product designation

Redback, Model CF2242/CF2243, type A, indoor, flush mount, emergency sound-system loudspeaker

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Altronic Distributors Pty Ltd 174 Roe Street, PERTH, WA, AUSTRALIA, 6000

Registrant

Altronic Distributors Pty Ltd 174 Roe Street, PERTH, WA, AUSTRALIA, 6000

Producer

Altronic Distributors Pty Ltd 174 Roe Street, PERTH, WA, AUSTRALIA, 6000

Conformance criteria and evaluation

The Redback, Model CF2242/CF2243, type A, indoor, flush mount, emergency sound-system loudspeaker has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian Standard AS ISO 7240.24:2018, 'Fire detection and alarm systems - Part 24: Fire alarm loudspeakers'.

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices .and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

David Whittaker

Executive Officer - ActivFire Scheme





Schedule to

Certificate of Conformity

Certificate num. Registration date		Version		Valid until	
afp - 3702	27-Oct-2022	Number 1	Issue date 27-Oct-2022	30-Apr-2024	Page 2 of 3

Producer's description

The Redback, Model CF2242/CF2243, type A, indoor, flush mount, emergency sound-system loudspeaker is designed to be flush-mounted into a suspended ceiling to provide emergency warning audible broadcasts. It is fitted with a 200 mm paper cone speaker driver and is rated for a maximum power output of 15 W when provided with an input signal of 100 Vac. Five taps are provided on the included transformer for operating at a range of output levels.

This product includes a metallic circular front grill, approximately 265 mm in diameter, with a concentric pattern of holes, plus a slip-on rear cover which is fitted with two lock-nut cable glands for connection to an emergency sound system. It is fitted with six retaining clips.

This is a type A loudspeaker intended for indoor applications only.

Technical specification

The following details are a representative extract of the technical specification for the Redback, Model CF2242/CF2243, type A, indoor, flush mount, emergency sound-system loudspeaker and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Schedule of variant designations

The following is a schedule of validated variant designations of the certified/listed equipment.

Variant			
Туре	Ident.	Description	Colour
Model	CF2242	Type A, indoor, flush-mount, emergency sound-system	White housing and grill
	CF2243	loudspeaker	Black housing and grill

Schedule of properties/characteristics

The following schedule is an extract of physical and operational properties/characteristics of the certified/listed equipment.

Rated noise power	15 Watts (100V line)			
Power taps & impedance	(100V line) 1.25W (8kΩ), 2.5W (4kΩ), 5W (2kΩ), 10W (1kΩ), 15W (668kΩ)			
Sensitivity	95dB (1W @ 1m), 83dB (1W @ 4m)			
Maximum Sound Pressure Level	106 dB (5W @ 1 m), 94dB (5W @ 4m)			
Frequency response	100Hz – 15kHz, 500-4kHz: ±8dB			
Coverage angle (-6dB)	500Hz: >180°, 1000Hz: >180°, 2000Hz: 85°, 4000Hz 55°			
Environmental	Type A (for indoor applications as per standard)			
Speaker component	200mm (8") paper cone speaker			
Mounting hole	246mmØ			
Mounting method	6 x plastic spring loaded clip			
Line monitoring	Yes, 22µF bipolar capacitor			
Applicable cable	2.5mm ² (14 AWG) max conductor area			
Connection	4-way screw terminal			
	White (CF2242) or Black (CF2243) aluminium grille			
Finish	Clear Flame retardant ABS spring clips (Makrolon 6557)			
	Red flame retardant ABS transformer dome cover (Starex VH-0800)			
Dimensions	266Ø x 103Dmm			
Weight	1.95kg			

Schedule to Certificate of Conformity

Certificate num.	Certificate num. Registration date		ersion	Valid until	
afp - 3702	27-Oct-2022	Number 1	Issue date 27-Oct-2022	30-Apr-2024	Page 3 of 3

Supplementary information

Schedule of relevant articles

The following schedule is an extract of articles significant and/or related as evidence of conformity.

Reference			Date issued		
Ident. type	Ident.	Title / description	(or date validated)	Source	
Report	XF3338/R7	Evaluation for Conformity of the Redback, Model CF2242/3, type A, indoor, flush mount, emergency sound-system loudspeaker to the requirements of AS ISO 7240.24:2018	30-Mar-2022	CSIRO, Fire Systems Laboratory, AU	
Data Sheet	CF2242	Redback Data Sheet CF2242 200mm (8") 100V 15W Ceiling Speaker White AS ISO7240.24 CF2243 200mm (8") 100V 15W Ceiling Speaker Black AS ISO7240.24 (CF2242 Datasheet 15-11-21.pdf)	15-Nov-2021	Altronic Distributors Pty Ltd, WA, AU	